

SUNRISE RECREATION and PARK DISTRICT
Net Climber at Arcade Creek Park Preserve

Project # 2019-12-ACPP

Engineers Estimate: \$18,000

Bids Due Thursday, January 23, 2020 on or before 2:00 PM
at 7801 Auburn Blvd., Citrus Heights, CA 95610

Pre-bid Walk Questions - Addenda #1

The following Questions were asked in regards to this project. The District's response is found to the right.

Question	Response
1 Plot update	As you can see, the plot is still being constructed. The stakes indicate the corners of the play area that are also reflected by an updated plot plan as noted on the District website. The total measurements have been reduced by 4 feet in length and narrowed by 1 foot.
2 Bid Addendums and updates.	Bid documents including addenda, revisions and bid results can be found on the Districts Website at: http://sunriseparks.com/about/bids-rfps/ . The last posting to the website for addendum will be 2:00 PM - 24 hours prior to the bid deadline.
3 Who is doing the install?	The District will perform the install with Factory Trained Qualified Supervision provided by the equipment vendor.
4 Is the Qualified Supervision part of the Bid Amount?	Yes, please include one day of Qualified Supervision in your proposal. If the District needs additional days, the District will contract directly with the Factory Trained Supervisor.
5 The proposal states that the District is looking for equipment that is under 8' high.	That is not quite correct. The District is looking for equipment that has a <i>critical fall height of 8'</i> as the District will be supplying Engineered Wood Fiber under the equipment. It is the District's understanding that most net climbers do not have an 8' fall height as they measure the maximum distance between horizontals as the critical fall height, even if the structure itself is well over 8'.