

**HISTORIC RUSCH HOME FULL ROOF REPLACEMENT
2021-04-RPH**

**PRE-BID WALK, APRIL 28, 2021
QUESTIONS**

1. Are the gutters to stay the same configuration?
Open to an upgrade of style on the gutters, possibly a 4" vs the current 2"
2. Additional Down spouts?
Are requesting 2 down spouts on front of house and 2 down spouts on back of house.
3. Leafguards?
Yes, interested in a leaf protection system for the gutters.
4. Decorative Brackets on eaves.
Do not appear to be for support but want to keep the look for historic reasons.
5. Historic look of shingles.
Need a minimum of 30 year and fire rating. Wood or another equivalent historic look and rating.